

NOT A CONSTRUCTION DETAIL





SECTION A-A NOT TO SCALE

STANDARD SIZES						
MODEL	x	Υ	MEDIA BAY	RECOMMENDED CATCHMENT DRAINAGE AREA*	TREATMENT FLOW RATE (CFS)*	MAX UNDERDRAI PIPE (DIA)
ST-6X4SUS	10	5	4' X 6'	UP TO 0.23	0.082	4"
ST-8X4SUS	12	5	4' X 8'	0.24-0.29	0.118	4"
ST-10X4SUS	14	5	4' X 10'	0.30-0.35	0.139	6"
ST-12X4SUS	16	5	4' X 12'	0.36-0.41	0.157	6"

BASED ON 3 OPEN SIDES

RASED ON 3 OPEN SIDES

TREATMENT FLOW RATES BASED ON C.0.95 OR CATCHMENTS WITH MAXIMUM IMPERVIOUS SURFACE
CONTACT STORMERE FOR ADDITIONAL DIMENSIONS
SIZING TRALE INTENDED FOR PLANNING LEVEL USE ONLY
CONTACT STORMERE PROPOR TO FINAL PLAN SUBMITTAL

STORMTREE.
INTERNAL SUMP SERIES
CURB ENTRY (SHORT SIDE)
W/INTERNAL BYPASS



Thinking Outside the Concrete Box...

24 Corliss Street, Suite 9092, Providence, RI 02940 (401) 626-8999 www.storm-tree.com
THIS DESIGN, DRAWING, AND TECHNICLOSY IS REPORTED AND THE PROPERTY OF STORMITREE. AND
MAY NOT BE ALTERED OR REPRODUCED WITHOUT THE EXPRESSED CONSENT OF STORMITREE
PATENT & U.S. 533,586, 10563,392, OTHER PATENTS PROBING